

LOCATION 203 Forest Hill CITY Gast.  
BETWEEN Tenth Ave. STREET & Hillside Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>86'</u>		<u>4-15-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>81'</u>			


ENTERS: SAME BRANCHED INTO:  
TAP SIZE. 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 165' From (C) of Tenth Ave.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY ONLY  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION Southside of Forest Hill

"A" P/S READING P. TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY