

LOCATION 310 E 4th Ave

CITY Gastonia

BETWEEN S. Willow

STREET &

Union Rd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	3'	4-20-93	Tied over	91'0" Ext
MAIN TO PROP. LINE					3/4" New Ser.	to Ext 2"
PROP. LINE TO BLDG.					Plastic Main	

ENTERS: 310

BRANCHED INTO: 0

TAP SIZE: 1/2

PRESSURE

100

P.S.I.

INCHES W.C.

LOCATION

17'50" East 4th
355 W of Co Willow

PRESSURE TEST: @

100 psi

For

14 Hrs.

By

EP

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1993

DEPTH:

3 Ft.

6

In.

LOCATION

"A" P/S READING

P

TOTAL ANODES


1*

17*

L.R. #

REMARKS:

Tracer wire tied off at main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S R. Ser	1.3
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY