

APPROX LOCATION 319 - E 4th - (Double meter site)

CITY Gastonia

BETWEEN 5th STREET & 4th STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	137'			
MAIN TO PROP. LINE	3/4	P	5'			5-15-93
PROP. LINE TO BLDG.	3/4	P	132'			

ENTERS: 319 - E 4th BRANCHED INTO: 505 S. Willow

TAP SIZE: 1/2 PRESSURE: 60 P.S.I. INCHES W.C. LOCATION


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EP

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1993

DEPTH: 3 Ft. 6 In. LOCATION

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY