


LOCATION 894 E. 4th AveCITY CASTONIABETWEEN Park TerraceSTREET & 902 E. 4th Ave.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>98'</u>	<u>7-27-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>68'</u>			

ENTERS: 894BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C.LOCATION 110' E of C of Park TerracePRESSURE TEST: @ 100 psi For 1/4 Hrs. By RLMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1989DEPTH: 3 Ft. 0 In. LOCATION 12' S of C of E. 4th Ave."A" P/S READING Plastic TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # 322626REMARKS: New 3/4 Plastic Service, with Road Bore.

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY