

LOCATION 1001 W. 4th ST. CITY GASTONIA

BETWEEN S. Weldon ST STREET & STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG | 3/4" | P | 57' | 1-22-99 | | |
| MAIN TO PROP. LINE | 3/4" | P | 10' | | | |
| PROP. LINE TO BLDG. | 3/4" | P | 47' | | | |

ENTERS: 1001 BRANCHED INTO.

TAP SIZE: 1/2" PRESSURE 600 PSI INCHES W C LOCATION 80' S. of center of

W. 4th ST


PRESSURE TEST: @ 100 PSI FOR 4 HRS BY S. Hufford

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED

DEPTH: 3 FT 0 IN LOCATION 14' W. of center of S. Weldon ST

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 35019

REMARKS:



| Test Station | | |
|--|------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY