

LOCATION 101 1/2 West 4th St. CITY Gastonia

BETWEEN DALTON STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	84'	10-17-01		
MAIN TO PROP LINE	5/8"	P	34'			
PROP LINE TO BLDG	5/8"	P	50'			

ENTERS Same BRANCHED INTO

TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION 13' South of West 4th St & 277' East of Dalton


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY B. BALLARD

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1991

DEPTH 3 FT 6 IN LOCATION 13' South of West 4th St.

"A" P/S READING Plastic TOTAL ANODES 1# 0 17# 0 LR # 0

REMARKS New Plastic Service



Test Station		
Reading & location	Lead	Volts
P/S Pipeline Lead Red New Service	S	p Riser
P/S Pipeline Lead White Existing Main	E	