

LOCATION 1117 W. 4th Ave. CITY GASTONIA

BETWEEN S. Dalton STREET & W. 5th Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>45'</u>	<u>11-2-99</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>40'</u>			

ENTERS 1117 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 521' W. of center of S. Dalton Ave.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.G.

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED

DEPTH 3 FT 0 IN LOCATION 19' S. of center of W. 4th Ave.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 938760

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	
P/S Pipeline Lead White Existing Main	E	