

LOCATION 1205 4th St.

CITY Gasloris

BETWEEN Boyd St.

STREET & Emerson

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	4'	11-5-94	tid over 80'	3/4" w ser.
MAIN TO PROP. LINE					to Ext 2"	P. main
PROP. LINE TO BLDG.						

ENTERS: 1205

BRANCHED INTO: —

TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION

12' N of C of
4th St.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By GP


MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ☒ YEAR INSTALLED 1991

DEPTH: 3 Ft. 0 In. LOCATION

"A" P/S READING P TOTAL ANODES 1# 1 17#

L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R	1.40
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY