

LOCATION 1212 W 4th ave CITY Gastonia
 BETWEEN S. Boyd St. STREET & EMERSON STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>93</u>	<u>11/1/00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>10</u>	<u>11</u>		
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>83</u>	<u>11</u>		

ENTERS 1212 W 4th ave BRANCHED INTO 0

TAP SIZE 1/2 PRESSURE 60 PSI _____ INCHES WC LOCATION 128 Ft East of center of S. Boyd St.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993

DEPTH 2' FT 8" IN LOCATION 12 Ft. north of center of W. 4th ave

"A" P/S READING plastic TOTAL ANODES 1# _____ 17# _____ LR # 01006771

REMARKS new plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>1.50</u>