

LOCATION 1335 W. 4th Ave. CITY Bastrop

BETWEEN Boyd St. STREET & Linwood Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>31'</u>	<u>1-03-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>20'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>11'</u>			

ENTERS 1335 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 214' E. of center of Linwood Rd.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN SIZE 3/4" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED

DEPTH 2 FT 0 IN LOCATION 50' S. of center of W. 4th St.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # —

REMARKS

