


LOCATION 3021 Foxborough CtCITY GastoniaBETWEEN River Ridge DrSTREET & Deadend

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	94'	2-22-54		
MAIN TO PROP. LINE	3/4	P	7'			
PROP. LINE TO BLDG.	3/4	P	87'			

ENTERS: 3021 Foxborough Ct BRANCHED INTO: -TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 131' N of River Ridge DrPRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. ElmoreMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992DEPTH: 3 Ft. 0 In. LOCATION 21' W of Foxborough Ct"A" P/S READING 40 TOTAL ANODES 1# _____ 17# _____ L.R. # 066046

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY