

LOCATION 2147 FOX HUNT DR. CITY GASTONIA
BETWEEN QUAIL HOLLOW CT. STREET & WINDYRUSH STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>36'</u>	<u>11-22-93</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>2'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>34'</u>			

ENTERS: 2147 BRANCHED INTO:
TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION EAST SIDE OF 2147

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By SA
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1977
DEPTH: 3 Ft. 0 In. LOCATION 50' WEST OF CENTER OF QUAIL HOLLOW CT.

"A" P/S READING .8 TOTAL ANODES 1* 17 * 1 L.R. # 00453769

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY