

LOCATION 2209 Fox Hunt Drive

CITY Gastonia

BETWEEN Dead end

STREET & Quail Hollow

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	102'	1-17-97		
MAIN TO PROP. LINE	3/4	P	10'			
PROP. LINE TO BLDG.	3/4	P	92'			

ENTERS: 2209

BRANCHED INTO:

TAP SIZE: 3/8

PRESSURE 60

PSI

INCHES W.C.

LOCATION 22' W OF Fox Hunt

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M Parker

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL X PLASTIC YEAR INSTALLED 1977


DEPTH: 3 FT. 0 IN. LOCATION 146' N OF Quail Hollow

"A" P/S READING 1.0

TOTAL ANODES 1# 17#

I.R. # 26607

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P-riser
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY