

LOCATION 3126 Frater Church Rd. CITY Castroville

BETWEEN Log Cabin Dr STREET & Path Dr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>70'</u>	<u>3-6-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>25'</u>			
PROP. LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>45'</u>			

ENTERS. 3126 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 600 PSI _____ INCHES W C LOCATION 254' w. of center of

Log Cabin Dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Huffaker

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 3 FT 0 IN LOCATION 12' S. of center of Frater Church Rd.

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 L.R. # 126840

REMARKS:

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	S	
	P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY