

LOCATION 605 & 613 FRANCIS CITY CARSON
BETWEEN WARD AVE STREET & LEROY AVE STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	202'	720 W 9/29/98		
MAIN TO PROP. LINE			20'			
PROP. LINE TO BLDG.			182'			

ENTERS: 605 & 613 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION NORTH SIDE OF 605
SOUTH SIDE OF 613

PRESSURE TEST @ 100 PSI FOR 4 HRS BY DF
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998
DEPTH: 3 FT 0 IN LOCATION West side of Francis St

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 2038590

REMARKS: Tied over 104' of Ex 3/4" Plastic Service to 605 Francis
to new main with 3' of 3/4" Plastic Pipe. Service to
613 is split with service to 605 (95' of Service to 613)
Ex Services AIR tested at 100# for leak.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY