

LOCATION Shrimp Boat 302 E. FRANKLIN BLDG. CITY Gastonia
BETWEEN Broad St. STREET & Willow STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	$\frac{3}{4}$	P	2'	4-19-93	tied over	of Pw
MAIN TO PROP. LINE					Pipe to P. Mine	
PROP. LINE TO BLDG.						

ENTERS: Shrimp Boat BRANCHED INTO: 0
TAP SIZE: $\frac{1}{2}$ PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION 23' W of C
of Broad St

PRESSURE TEST: @ 100 psi For $\frac{1}{4}$ Hrs. By JP
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992
DEPTH: 3 Ft. 0 In. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Did NOT see the EXT $\frac{3}{4}$ TRANS. & DRESSER



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>1.00</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY