


LOCATION 320 E. FranklinCITY GastoniaBETWEEN Broad st.STREET & Willow

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>2'</u>	<u>4-20-93</u>	<u>tied over</u>	<u>127' of 3/4</u>
MAIN TO PROP. LINE					<u>9/4 Ser.</u>	<u>to P. Main</u>
PROP. LINE TO BLDG.						

ENTERS: 320BRANCHED INTO: 316

TAP SIZE: <u>1/2</u>	PRESSURE <u>60</u> P.S.I.	INCHES W.C.	LOCATION <u>33' S of C of E. Franklin</u>
----------------------	---------------------------	-------------	---

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EPMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1992DEPTH: 3 Ft. 0 In. LOCATION"A" P/S READING P TOTAL ANODES 1* 17* L.R. # REMARKS: tied wire off at Main

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>1.00</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY