

LOCATION 601 E-Franklin CITY BASTONIA  
BETWEEN Franklin Blvd. STREET & 2nd Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>3'</u>	<u>10-14-93</u>	<u>Tied over 68' 3/4 Plastic</u>	
MAIN TO PROP. LINE					<u>on 601 Tied over 50' 3/4</u>	
PROP. LINE TO BLDG.					<u>Plastic on 204 S. Hwy.</u>	

ENTERS: 601 E-Franklin BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 178' S of C of Franklin Blvd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I.     BARE STEEL     COATED STEEL     PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 16' W of C of Hwy St.

"A" P/S READING P TOTAL ANODES 1\*     17\*     L.R. #    

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY