

LOCATION 711 E. Franklin Blvd. CITY GAstonia
 BETWEEN Chestnut STREET & DAVIS St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>10'</u>	<u>4-9-94</u>	<u>Tied over 74'</u>	<u>4-14-88</u>
MAIN TO PROP. LINE					<u>Existing 3/4'</u>	
PROP. LINE TO BLDG.					<u>PLASTIC</u>	


 ENTERS: 711 E. Franklin BRANCHED INTO: 703, 705, 707 E. Franklin
 TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 92' E of C of DAVIS St.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL
 MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992
 DEPTH: 3 Ft. 0 In. LOCATION 30' S of C of E. Franklin Blvd.

"A" P/S READING P TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS: 703, 705, 707 Branches off 711 See W.O.#114070

~~Bare~~ Main Replacement
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY