

LOCATION 728 E. Franklin Blv. CITY Oakstonia
BETWEEN Chestnut STREET & Axon STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>101'</u>	<u>Replaced. 8-4-98</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS 728 BRANCHED INTO: -
TAP SIZE: 3/4 Ser. PRESSURE 60 PSI INCHES W C LOCATION

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY EP
MAIN SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1991
DEPTH: 2 FT 0 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY