

LOCATION 913 E FRANKLIN BLVDCITY GASL.BETWEEN Franklin Blvd

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>115'</u>			<u>5-14-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>3'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>113'</u>			

ENTERS: SAME


BRANCHED INTO:

TAP SIZE: 3/4"PRESSURE 60 PSI _____ INCHES W.C.LOCATION 91' from (A) of
Franklin BlvdPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DNJMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997DEPTH: 3 FT 0 IN LOCATION westside of Poplar st."A" P/S READING P.

TOTAL ANODES 1# _____ 17# _____

L.R. # _____

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY