

LOCATION 917 E. FRANKLIN CITY GASTON

BETWEEN Poplar STREET & Belvedere STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>2'</u>	<u>4-8-99</u>		
MAIN TO PROP LINE						
PROP LINE TO BLDG						

ENTERS 917 BRANCHED INTO —

TAP SIZE 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST @ 100 PSI FOR 4 HRS BY SE

PIPE SIZE 3/4" Sg C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 99

DEPTH 1 FT 4 IN LOCATION _____ 5-13-97

"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ LR# _____

REMARKS Replace 3/4 Plastic pipe - service ran through
sewer line



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Plastic</u>	<u>0.0</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	