

LOCATION 1002 E. FRANKLIN

CITY Gastonia

BETWEEN DEPIAN

STREET & Belvedere

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	173			
MAIN TO PROP. LINE	3/4	P	80			10-31-96
PROP. LINE TO BLDG.	3/4	P	93			

ENTERS: 1002 E FRANKLIN

BRANCHED INTO: 1000 E FRANKLIN (DADA JOHN PIZZANO)

TAP SIZE: 3/8

PRESSURE 20 PSI

INCHES W.C.

LOCATION

PRESSURE TEST: @ 105 PSI FOR 1 1/4 HRS. BY EP

MAIN-SIZE 4"

C.I.

BARE STEEL ☒

COATED STEEL

PLASTIC

YEAR INSTALLED

DEPTH: 3 FT. 6 IN.

LOCATION


"A" P/S READING 16

TOTAL ANODES 1# 0 17# 1

L.R. #

REMARKS:

Left 3/4 Stub at Riser of #1002 E. Franklin for
New Service going to #1,000 E. Franklin.



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Plastic
P/S Pipeline Lead - White Existing Main	E	