

LOCATION 1133 E. Franklin Blvd.CITY GastoniaBETWEEN Patrick St.STREET & Element Ave.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>26'</u>		<u>5-23-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>3'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>23'</u>			

ENTERS: SAMPBRANCHED INTO: 1131 E Franklin Blvd.

TAP SIZE <u>3/4"</u>	PRESSURE <u>60</u> PSI	INCHES W.C. _____	LOCATION <u>305' From @ of Patrick St.</u>
----------------------	------------------------	-------------------	--


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DH

MAIN-SIZE <u>4"</u>	C.I. _____	BARE STEEL _____	COATED STEEL _____	PLASTIC <input checked="" type="checkbox"/>	YEAR INSTALLED <u>1987</u>
---------------------	------------	------------------	--------------------	---	----------------------------

DEPTH: 3 FT 0 IN. LOCATION South side of Franklin Blvd.

"A" P/S READING <u>P.</u>	TOTAL ANODES 1# <u>-</u> 17# <u>-</u>	L.R. # <u>-</u>
---------------------------	---------------------------------------	-----------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY