

LOCATION 1134 E. FRANKLIN BLVD. CITY GASTONIA

BETWEEN PATRICK ST. STREET & EDGEMONT AVE. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>201'</u>		<u>5-</u>	<u>27-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>18'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>123'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 260' From @ of

PATRICK ST.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DHJ.

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION SOUTHside of Franklin Blvd.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		