

LOCATION 1138 E. Franklin Blvd. CITY DARTONIA
 BETWEEN Edge Mont STREET & Patrick STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>175'</u>	<u>3-21-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>80'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>95'</u>			

ENTERS: 1138 BRANCHED INTO: 0
 TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 163' W of C of Edge Mont


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 4" C.I. _____ BARE STEEL ☒ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1949

DEPTH. FT. IN. LOCATION 40' S of C of E. Franklin Blvd.

"A" P/S READING .600 TOTAL ANODES 1# _____ 17# 1 L.R. # 131219

REMARKS:



Test Station		
Reading & Location	Lead	-Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY