

LOCATION 1204 E. Franklin Blvd. CITY Castroville
BETWEEN N Edgemont Ave STREET & Thomas St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>40</u>	<u>7-10-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>15'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>25'</u>			

ENTERS 1204 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 137' N. of center of
E. Franklin Blvd.

PRESSURE TEST @ 100 PSI FOR 114 HRS BY S.H.

MAIN-SIZE 3/4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH 2 FT 0 IN LOCATION 98' E. of center of N. Edgemont Ave

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 537378

REMARKS

