

LOCATION 1208 E Franklin Blvd. CITY Gastonia

BETWEEN Edgemont Ave. STREET & Poston Cir STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>188'</u>			<u>S-30-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>78'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>110'</u>			

ENTERS: SAMP BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 362' from E of

Edgemont Ave.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS. BY D.H.

MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION South Side of Franklin Blvd.

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY