

LOCATION 1320 E Franklin St CITY Boston  
BETWEEN Thomco St STREET & Beverly STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>22</u>	<u>8-24-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>22</u>			

ENTERS: 1320 BRANCHED INTO:  
TAP SIZE: 3/8 PRESSURE \_\_\_\_\_ P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION Inside of Bldg

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Jennett  
MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED Not on Record  
DEPTH: 2 Ft. 6 In. LOCATION 35' S of Craig St

"A" P/S READING 070 TOTAL ANODES 1# \_\_\_\_\_ 17# 1 L.R. # 00369061

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY