

LOCATION 1400 E Franklin Blvd CITY GASTONIA

BETWEEN ORNDORF STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED <i>Relocate</i>	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Pan</u>	<u>21'</u>	<u>1/24/95</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 1400 BRANCHED INTO:

TAP SIZE: 3/8" PRESSURE 60 P.S.I. INCHES W.C. LOCATION North side of 1400

PRESSURE TEST: @ 160 psi For 1/4 Hrs. By DT


MAIN - SIZE 3/4" C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1967

DEPTH: 1 Ft. 6" In. LOCATION North side of 1400

"A" P/S READING 1.60 TOTAL ANODES 1 * 1 17 * 0 L.R. #

REMARKS:

P.S. Reading on Riser made after anode
Installed



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R.</u>	<u>1.60</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY