

LOCATION 1400 E FRANKLIN BLVD.CITY CASPER, WY.BETWEEN Belvedere Ave.STREET & BEVERLY ST.

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>400'</u>		<u>6-</u>	<u>18-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>94'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>308'</u>			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/8"PRESSURE 60 PSI _____ INCHES W.C.LOCATION 744' from @ of
Belvedere Ave.PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.H.F.MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____DEPTH: 3 FT 0 IN LOCATION southside of Franklin"A" P/S READING .9TOTAL ANODES 1# - 17# -L.R. # -

REMARKS:



Test Station

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service**S**P/S Pipeline Lead - White
Existing Main**E**

ENG. DEPT. USE ONLY