

LOCATION 1510 E. Franklin Blv. CITY Castoria
BETWEEN Beverly Dr. STREET & N. New Hope Rd STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED <input checked="" type="checkbox"/>	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>D</u>	<u>38'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>D</u>	<u>10'</u>		<u>9-28-35</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>D</u>	<u>28'</u>			

ENTERS: 105 N. New Hope BRANCHED INTO: 1510 E. Franklin Blv.
TAP SIZE: 1" Ser. PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By E.P.
MAIN-SIZE 1" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1957
DEPTH: 2 Ft. 6 In. LOCATION _____

"A" P/S READING 1.1 TOTAL ANODES 1* 0 17* 0 L.R. # _____

REMARKS: Used Ext Muller Tee



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY