

COPY

LOCATION 1601 E. Franklin Blvd. CITY GASTONIA
 BETWEEN E. Franklin Blvd. STREET & BURTON WOOD STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	2"	PLASTIC	298'	3-19-01		
MAIN TO PROP LINE	2"	PLASTIC	23'			
PROP LINE TO BLDG	2"	PLASTIC	275'			


ENTERS 1601 BRANCHED INTO 0
 TAP SIZE _____ PRESSURE 60 PSI _____ INCHES W C LOCATION 323' N of C of Burton Wood Dr.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN SIZE 4" C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1965
 DEPTH 3 FT 0 IN LOCATION 32' E of C of S. New Hope Rd.

"A" P/S READING .75 TOTAL ANODES 1# _____ 17# 1 LR # _____

REMARKS Installed 17th Anode Reading Came up to .80 Old Shoneys Building



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser
P/S Pipeline Lead - White Existing Main	E	PLASTIC