

LOCATION 1654 E. FRANKLIN BLVD CITY East

BETWEEN New Hope Rd. STREET & BRIDGE LN. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>93'</u>		<u>7-</u>	<u>29-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>87'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 621' from E of

New Hope Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.F.

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT 2 IN. LOCATION N OF FRANKLIN BLVD.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY