

LOCATION 2022 E Franklin Blvd CITY GASTONIA
BETWEEN E Club DR STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	79'	10/21/96		
MAIN TO PROP. LINE	3/4"		35'			
PROP. LINE TO BLDG.	3/4"		44'			

ENTERS: 2022 BRANCHED INTO:
TAP SIZE: 3/8" PRESSURE 60 P.S.I. INCHES W.C. LOCATION E Side of 2022

PRESSURE TEST: @ 100 psi For 44 Hrs. By DJ
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1967
DEPTH: 2 Ft. 6 In. LOCATION East side of E Club DR

"A" P/S READING .70 TOTAL ANODES 1* 0 17* 1 L.R. # 580717

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY