

LOCATION 2150 & 2022 E. Franklin Blvd. CITY Gastonia  
BETWEEN Green St STREET & STREET

	SIZE	TYPE	2150	2022	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	D	1981	9'			
MAIN TO PROP LINE	3/4	D	5'	1'		10-6-99	
PROP LINE TO BLDG	3/4	D	1981	8'			

ENTERS 2150 BRANCHED INTO 2022

TAP SIZE 1 1/4 Tee PRESSURE 60 PSI INCHES WC LOCATION


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY LD

MAIN SIZE 4" C I BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1953

DEPTH 4 FT 6 IN LOCATION

"A" P/S READING .85 TOTAL ANODES 1# 0 17# 0 LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	.85
P/S Pipeline Lead White Existing Main	E	