

LOCATION 2300 E. Franklin Blvd. CITY GASTONIA  
BETWEEN Glenwood Dr. STREET & EAST CLUB Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	2"	Plastic	158'	4-22-02		
MAIN TO PROP LINE	2"	Plastic	8'			
PROP LINE TO BLDG	2"	Plastic	150'			

ENTERS 2300 BRANCHED INTO 0  
TAP SIZE \_\_\_\_\_ PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 725' E of Prop East Club Dr.

PRESSURE TEST @ 100 PSI FOR 3 HRS BY RL ✓

MAIN-SIZE 4" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1964

DEPTH 4 FT 0 IN LOCATION 51' N of Prop E. Franklin Blvd.

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ LR # \_\_\_\_\_

REMARKS

2" Service - Tested Same As Main 3 Hrs.  
Test Chart Attached.

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	Riser.
P/S Pipeline Lead - White Existing Main	E	Plastic

