

LOCATION 2384 E. Franklin Blvd. CITY Canton

BETWEEN Glenwood Dr. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>84'</u>	<u>12-13-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>84'</u>			

ENTERS 2384 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 183' W. of center of Glenwood Dr


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S. et

MAIN SIZE 3/4" C I BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1974

DEPTH 3 FT 0 IN LOCATION 141' N. of center of E. Franklin Blvd.

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 LR # 1157328

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	