

LOCATION 2830 E. Franklin Bld CITY Gastonia
BETWEEN Hanaford Drive way STREET & Home Dept Ent. STREET.


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>6'</u>	<u>10-14-97</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>0'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>6'</u>			

ENTERS: 2830 BRANCHED INTO: 0
TAP SIZE: 3/4 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 425' W. of cot
Home depot Main Ent

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By _____
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997
DEPTH: 3 Ft. In. LOCATION 9' S. of cot Hanaford Dr.

"A" P/S READING Plastic TOTAL ANODES 1# - 17# - L.R. # ~

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY