

LOCATION 2870 E. FRANKLIN Blvd. CITY GASTONIA
BETWEEN Cox Rd. STREET & Church STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>2"</u>	<u>P</u>	<u>390'</u>	<u>10.31.94</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>90'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>300'</u>			

ENTERS: 2870 E. FRANKLIN Blvd. BRANCHED INTO:

TAP SIZE: _____ PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION W. Side of Building


PRESSURE TEST: @ 100 psi For 24 Hrs. By RL

MAIN-SIZE 4" C.I. 1" BARE STEEL _____ COATED STEEL / PLASTIC _____ YEAR INSTALLED 1989

DEPTH: 4 Ft. _____ In. _____ LOCATION S. Corner of Franklin Square Parking Lot

"A" P/S READING 1.1 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: 2" ANODELESS RISER



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY