

LOCATION 2980 E. Franklin Blv. Ste 1 CITY Castonia

BETWEEN _____ STREET & _____ STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED <input checked="" type="checkbox"/> | RENEWED |
|---------------------|------------|----------|------------|-----------|---|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>P</u> | <u>250</u> | | | |
| MAIN TO PROP. LINE | <u>3/4</u> | <u>P</u> | <u>0</u> | | <u>8-26-98</u> | |
| PROP. LINE TO BLDG. | <u>3/4</u> | <u>P</u> | <u>250</u> | | | |

ENTERS. 2980 BRANCHED INTO Ste 1-2-3-4

TAP SIZE 3/8 PRESSURE 60 PSI _____ INCHES W C LOCATION _____

PRESSURE TEST: @ 100 PSI FOR 144 HRS BY EP

MAIN-SIZE 4" C I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1989

DEPTH: 4 FT 0 IN LOCATION _____

"A" P/S READING 1.3 TOTAL ANODES 1# 0 # 0 L R. # _____

REMARKS: _____

| Test Station | | | ENG. DEPT. USE ONLY |
|--|----------|----------------|---------------------|
| Reading & Location | Lead | Volts | |
| P/S Pipeline Lead - Red New Service | <u>S</u> | <u>Plastic</u> | |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | | |

Main - White

Service - Red

A