

LOCATION 3020 E Franklin Blvd. CITY Gastonia

BETWEEN Cok Rd. STREET & Church St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>21'</u>	<u>11-3-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>21'</u>			

ENTERS 3020 BRANCHED INTO

TAP SIZE: 1/2 PRESSURE 60 PSI          INCHES W C LOCATION 20' E. of corner of

Building


PRESSURE TEST @ 100 PSI FOR 4 HRS BY S. Huffstetter

MAIN-SIZE 4" C.I.          BARE STEEL          COATED STEEL ✓ PLASTIC          YEAR INSTALLED         

DEPTH 2 FT 0 IN LOCATION 20' N. of center of Back of Building

"A" P/S READING 1.4 TOTAL ANODES 1# 0 17# 0 L.R. # 265140

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY