


LOCATION 3090 E. Franklin BlvdCITY GastoniaBETWEEN Church St.STREET & Cox Rd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>65'</u>	<u>5-23-95</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>7'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>58'</u>			

ENTERS: 3090BRANCHED INTO: —TAP SIZE: 1/2 PRESSURE — P.S.I. — INCHES W.C. LOCATION 7' N. of C ofdrive in Franklin squarePRESSURE TEST: @ 100 psi For 1/4 Hrs. By JPMAIN-SIZE 4" C.I. — BARE STEEL — COATED STEEL ✓ PLASTIC — YEAR INSTALLED 1980DEPTH: 3 Ft. 0 In. LOCATION —"A" P/S READING 1.100 TOTAL ANODES 1\* — 17\* — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY