

LOCATION 3250 E. Franklin Blvd. CITY GASTONIA  
BETWEEN Cox Rd. STREET & Church St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	2"	Plastic	685'	11-29-94		
MAIN TO PROP. LINE	2"	Plastic	75'			
PROP. LINE TO BLDG.	2"	Plastic	610'			

ENTERS: 3250 BRANCHED INTO: 0

TAP SIZE: 2" straight PRESSURE 60 P.S.I. INCHES W.C. LOCATION 2821' W of Caf Church St.  
Plastic Tee

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DL


MAIN-SIZE 2" C.I.      BARE STEEL      COATED STEEL      PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 3 Ft. 0 In. LOCATION 167' N of Caf Wilkinson Blvd.

"A" P/S READING Plastic TOTAL ANODES 1# 2 17#      L.R. #     

REMARKS: Two 1# Anode installed on Tracer wire for Service -  
One in Bell Hole At Tee

More Detailed Drawing Attached.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY