

LOCATION 3648 E. Franklin Blvd

CITY Gastonia

BETWEEN Church St

STREET &amp; Cox Rd.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	PL	47'	3-30-98		
MAIN TO PROP. LINE	3/4	PL	0	3-30-98		
PROP. LINE TO BLDG.	3/4	PL	47'	3-30-98		

ENTERS: Same

BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 4' South of North West  
Corner of Building


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY T. Loman

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 1998

DEPTH: \_\_\_\_\_ FT. \_\_\_\_\_ IN. LOCATION 47' West of Back of Building

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY