

LOCATION 3700 E Franklin Blvd.CITY GASTONIABETWEEN ChurchSTREET & - MDC Entrance

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>370</u>	<u>12-12-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>				
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>				

ENTERS: 3700

BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 116' N OFE FranklinPRESSURE TEST: @ 100 psi For 1/4 Hrs. By M ParkerMAIN-SIZE 6" C.I. _____ BARE STEEL _____ COATED STEEL X PLASTIC _____ YEAR INSTALLED 1987DEPTH: 3 Ft. 0 In. LOCATION 36' W OF MDC Entrance"A" P/S READING 2.0 TOTAL ANODES 1# 0 17# L.R. # -

REMARKS:

Test Station

ENG. DEPT. USE ONLY

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

S

PRISERP/S Pipeline Lead - White
Existing Main

E

