


LOCATION 3708 E Franklin BlvdCITY GASTONIABETWEEN Cox RdSTREET & Church St

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	2"	P	90'	10-7-94		
MAIN TO PROP. LINE	2"	P				
PROP. LINE TO BLDG.	2"	P				

ENTERS: 3708BRANCHED INTO: —TAP SIZE: 1 1/2 PRESSURE 60 P.S.I. — INCHES W.C. LOCATION 33' south ofFab shop DrivePRESSURE TEST: @ 100 psi For 26 Hrs. By M ParkerMAIN-SIZE 6" C.I. — BARE STEEL — COATED STEEL X PLASTIC — YEAR INSTALLED 1987DEPTH: 3 Ft. 0 In. LOCATION 24' W OF MAIN Entrance"A" P/S READING 2.0 TOTAL ANODES 1* — 17* — L.R. # 424922REMARKS: ANODELESS RISER

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P-RISER
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY