

LOCATION 3758 E. Franklin Blvd. CITY GASTONIA

BETWEEN Cox Rd. STREET & Church St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	34'	10-12-98		
MAIN TO PROP. LINE	3/4"	P	0			
PROP LINE TO BLDG.	3/4"	P	34'			

ENTERS 3758 BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI INCHES W C LOCATION 110' S. of center of

PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY S. Huffstetler Driveway

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3 FT 0 IN LOCATION 17' E. of center of Brick Alley

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 2105425

REMARKS:

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	S		
P/S Pipeline Lead - White Existing Main	E		

