

LOCATION 4027, 4037, 4039, 4041 E. FRANKLIN BLD CITY Gastonia
BETWEEN Norfolk STREET & Church STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>250</u>		<u>7-19-00</u>	
MAIN TO PROP LINE	<u>11</u>	<u>"</u>	<u>6'</u>			
PROP LINE TO BLDG	<u>11</u>	<u>"</u>	<u>244</u>			


ENTERS 4027 BRANCHED INTO 4037, 4039, 4041
TAP SIZE 1/2 PRESSURE _____ PSI _____ INCHES W C LOCATION 45' S of Cap

PRESSURE TEST @ 100 PSI FOR 14 HRS BY JP E. Franklin
MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 2 FT 6 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	