

LOCATION 820 W. Franklin Blvd CITY GASTONIA
BETWEEN Hill St STREET & S Weldon STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>76'</u>	<u>10/10/97</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>55'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>21'</u>			

ENTERS: 820 W. Franklin BRANCHED INTO: 905 Brewett St
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION _____


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY SE

MAIN-SIZE 3/4 Sec C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED _____

DEPTH: 1 FT. 6 IN LOCATION _____

"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # 673321

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY